


think:water
Profine[®]



Profine[®] *silver* CERTIFICATIONS





think:water

Via delle Pezze 35
35013 Cittadella (PD) Italy
Cap. Soc. € 90.000,00 i.v. - C.F. e P.I. IT 03985480288
REA PD: 352571 - Codice SDI: AU7YEU4

T. +39 049 9403792
F. +39 049 5971699
E. info@thinkwater.com

Our goal at TW has always been to create high quality products in compliance with requirements we consider to be mandatory when working with an element as important as Water.

Water is first and foremost a food. For this reason we believe it is imperative to guarantee utmost reliability. With this in mind, we wanted to reinforce the value of our product certification through a third-party and independent certifying body such as ICIM, the Italian Certification Institute for Mechanics. The company decision to certify our products was the result of the desire to inform consumers of the high quality of think:water filters and osmosis systems.


Water.

The term water implies the ICIM certification applicable to 9 legal guidelines resulting from ministerial, legislative, presidential decrees and EU directives (*see extract of regulations*). **Among these, the most important Ministerial Decree 174 for materials and objects that can be used in fixed systems for the treatment of water intended for human consumption and consequently Ministerial Decree 25.**

thinkwater.com

UNI EN ISO 9001:2015
UNI EN ISO 14001:2015
ICIM Food Contact Materials
ICIM Water Contact Materials

think:water



CERTIFICATION

IAPMO NSF

IAPMO RESEARCH AND TESTING, INC.

4755 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



LEAD FREE

CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued to:

THINK WATER Srl

VIA DELLE PEZZE, 35
CITTADELLA, PADUA 35013
Italy

Product:

Lead Free Water Filtration Product

Products are certified to the following standard(s):

Section 1417(d) of the Safe Drinking Water Act The lead content requirements of Section 116875 of the California Health & Safety Code NSF/ANSI/CAN 372- 2022

File Number: W-16225

Effective Date: December 2024


Chairman, Product Certification Committee



Revised Date: April, 17 2025

Void After Date: December 2029*


Chief Technical Service Officer

* This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

LEAD FREE

Issued To: THINK WATER Srl

Effective Date: December 2024

File Number: W-16225

Revised Date: April, 17 2025

Product: Lead Free Water Filtration Product

Void After: December 2029

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Product may be unmarked. If a certification mark is used, it shall include: - The certified company name. - The model number or trade designation. - The appropriate certification mark. The product may also bear either "Lead Free" or "Low Lead" above or in close proximity to the certification mark. Product markings may be permanently fixed on the system or may be included as part of product literature or packaging.

Characteristics:

Products may include any pipe, pipe fitting, solder, flux, or other plumbing products providing water for human consumption. Products listed below are to be installed in accordance with the manufacturer's instruction. These products have been verified with weighted average lead content $\leq 0.25\%$; Solder and flux lead content $\leq 0.2\%$.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Issued To: THINK WATER Srl

Effective Date: December 2024

LEAD FREE

File Number: W-16225

Revised Date: April 17, 2025

Product: Lead Free Water Filtration Product

Void After Date: December 2029

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Product Type	Plumbed-in	
Brand Name	Model Number	Replacement Component
Profine	Blue Small w/ Head ¹	Blue Small
Profine	Blue Medium w/ Head ¹	Blue Medium
Profine	Blue Large w/ Head ¹	Blue Large
Profine	Blue Sky Mini w/ Head ¹	Blue Sky Mini
Profine	Blue Sky Small w/ Head ¹	Blue Sky Small
Profine	Blue Sky Medium w/ Head ¹	Blue Sky Medium
Profine	Blue Sky Large w/ Head ¹	Blue Sky Large
Profine	Gold Small w/ Head ¹	Gold Small
Profine	Gold Medium w/ Head ¹	Gold Medium
Profine	Gold Large w/ Head ¹	Gold Large
Profine	Silver Mini w/ Head ¹	Silver Mini
Profine	Silver Small w/ Head ¹	Silver Small
Profine	Silver Medium w/ Head ¹	Silver Medium
Profine	Silver Large w/ Head ¹	Silver Large
Profine	Profine UNO	Replacement Filter UNO Silver

¹ Available with the following mounting hardware options:

Sizes: 8mm, 10mm, 1/4", 3/8"

Styles: circular bracket, circular bracket w/ no return valve, wall bracket, wall bracket w/ no return valve

Head Type: Series, Single-side, Parallel

Product Type Systems with Storage Tank and Automatic Shut-off Valve

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING

Issued To: THINK WATER Srl

Effective Date: December 2024

LEAD FREE

File Number: W-16225

Revised Date: April 17, 2025

Product: Lead Free Water Filtration Product

Void After Date: December 2029

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Model Number

Zero

Zero Professional

IAPMO RESEARCH AND TESTING, INC.

4755 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued to:

THINK WATER Srl

VIA DELLE PEZZE, 35
CITTADELLA, PADUA 35013
Italy

Product:

Drinking Water Treatment Unit - Aesthetic Effects

Products are in compliance with the following code(s):


Uniform Plumbing Code (UPC®)

Products are certified to the following standard(s):

NSF/ANSI 42-2022

File Number: W-16226

Effective Date: April 2025


Chairman, Product Certification Committee



Void After Date: April 2030*


Chief Technical Service Officer

* This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: THINK WATER Srl

Effective Date: April 2025

File Number: W-16226

Void After: April 2030

Product: Drinking Water Treatment Unit - Aesthetic Effects

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Product shall bear: The certified company name. The model number or trade designation. The appropriate certification mark. Product markings may be permanently fixed on the system or may be included as part of product literature or packaging.

Characteristics:

Point-of-use and point-of-entry systems intended to reduce substances affecting the aesthetic quality of the water or to add chemicals for scale control, or both. Certification demonstrates that all materials safety and structural integrity (as applicable) requirements have been met. To be installed in accordance with the manufacturer's installation instructions and the requirements of the latest edition of the Uniform Plumbing Code®. Point-of-Entry products certified to this standard also comply with the health effects materials safety requirements listed in NSF/ANSI 61.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: THINK WATER Srl

File Number: W-16226

Product: Drinking Water Treatment Unit - Aesthetic Effects

Effective Date: April 2025

Void After Date: April 2030

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Product Type	Plumbed-in				
Brand Name	Model Number	Replacement Component	Flow Rate (LPM)	Capacity (Liters)	Reduction Claims
Profine	Blue Small w/ Head ¹	Blue Small	5.21	19,900	Chlorine, Taste & Odor
Profine	Blue Medium w/ Head ¹	Blue Medium	8.11	31,000	Chlorine, Taste & Odor
Profine	Blue Large w/ Head ¹	Blue Large	11.77	45,000	Chlorine, Taste & Odor
Profine	Blue Sky Mini w/ Head ¹	Blue Sky Mini	3.79	14,450	Chlorine, Taste & Odor
Profine	Blue Sky Small w/ Head ¹	Blue Sky Small	5.21	19,900	Chlorine, Taste & Odor
Profine	Blue Sky Medium w/ Head ¹	Blue Sky Medium	8.11	31,000	Chlorine, Taste & Odor
Profine	Blue Sky Large w/ Head ¹	Blue Sky Large	11.77	45,000	Chlorine, Taste & Odor
Profine	Gold Small w/ Head ¹	Gold Small	5.21	19,900	Chlorine, Taste & Odor
Profine	Gold Medium w/ Head ¹	Gold Medium	8.11	31,000	Chlorine, Taste & Odor
Profine	Gold Large w/ Head ¹	Gold Large	11.77	45,000	Chlorine, Taste & Odor
Profine	Silver Mini w/ Head ¹	Silver Mini	3.79	14,450	Chlorine, Taste & Odor
Profine	Silver Small w/ Head ¹	Silver Small	5.21	19,900	Chlorine, Taste & Odor
Profine	Silver Medium w/ Head ¹	Silver Medium	8.11	31,000	Chlorine, Taste & Odor
Profine	Silver Large w/ Head ¹	Silver Large	11.77	45,000	Chlorine, Taste & Odor



CERTIFICATION

ICIM



Certificazione di Prodotto *Product Certification*

Certificato N.
Certificate No.

ICIM-CAP-009846-02

ALL'AZIENDA / TO THE FIRM

THINK WATER S.R.L. UNIPERSONALE

VIA DELLE PEZZE, 35 35013 CITTADELLA PD IT - Italia

UNITÀ OPERATIVE / OPERATIVE UNITS

VIA DELLE PEZZE, 35 35013 CITTADELLA PD IT - Italia

PER I SEGUENTI PRODOTTI / FOR THE FOLLOWING PRODUCTS

**Cartucce e testate filtranti per acqua potabile.
*Water filter cartridges and head.***

CON DENOMINAZIONE COMMERCIALE / WITH TRADE NAME/S

Uno
Profine Blue small/medium/large
Profine Blue Sky mini/small/medium/large
Profine Silver mini/small/medium/large
Profine Gold small/medium/large
Profine Cobalt small
Profine Platinum mini/small/medium
Kit Profine Silver mini/small/medium
Kit Profine Gold small/medium
Testate Profine

CONFORMEMENTE AL DOCUMENTO NORMATIVO ICIM NELLA REVISIONE CORRENTE ALLA DATA DI EMISSIONE
IN COMPLIANCE WITH ICIM NORMATIVE DOCUMENT IN THE CURRENT REVISION AT THE DATE OF ISSUE

0415CS

**Prodotti e componenti utilizzati a contatto con acqua destinata al consumo umano
(acqua potabile) sulla base di riferimento delle indicazioni del DM n. 174/2004.
Products and components in contact with water intended for human consumption
(drinking water) on the basis of the indications of Ministerial Decree nr. 174/2004**

Vincenzo Delacqua
Rappresentante Direzione / Management Representative

ICIM S.p.A.

PRIMA EMISSIONE
FIRST ISSUE

10/03/2020

EMISSIONE CORRENTE
CURRENT ISSUE

10/03/2025

DATA DI SCADENZA
EXPIRING DATE

09/03/2030

LIST OF REGULATIONS

DRINKING WATER TREATMENT SYSTEM

STANDARD OF REFERENCE

Rules and Regulations valid at the date of this document

REGULATIONS

ICIM 0001CR ICIM General Regulations

ICIM 0003CR Rules for the certification of products and services

ICIM 0260CR ICIM S.p.A. Certification Mark User Manual

LAW

Decreto Ministero della Salute 6 aprile 2004 n°174 "Regolamento concernente i materiali e gli oggetti che possono essere utilizzati negli impianti fissi di captazione, trattamento, adduzione e distribuzione delle acque destinate al consumo umano"

Decreto Ministero della Salute 21 marzo 1973 "Disciplina igienica degli imballaggi, recipienti, utensili, destinati a venire in contatto con le sostanze alimentari o con sostanze d'uso personale" e s.m.i."

Decreto del Presidente della Repubblica n. 777 del 23 agosto 1982 "Attuazione della direttiva (CEE) n. 76/893 relativa ai materiali e agli oggetti destinati a venire a contatto con i prodotti alimentari"

Decreto Ministero della Salute 4 aprile 1985 "Disciplina degli oggetti in ceramica destinati ad entrare in contatto con i prodotti alimentari"

Decreto Legislativo n. 108 del 25 gennaio 1992 "Attuazione della direttiva n. 89/109/CEE concernente i materiali e gli oggetti destinati a venire a contatto con i prodotti alimentari"

Decreto Ministero della Salute 18 aprile 2007 n° 76 "Regolamento recante la disciplina igienica dei materiali e degli oggetti di alluminio e di leghe di alluminio destinati a venire a contatto con gli alimenti".

Reg. UE n. 10/2011 on plastic materials and articles intended to come into contact with food

COUNCIL DIRECTIVE 98/83/CE of 3 November 1998 on the quality of water intended for human consumption

Decreto Legislativo 2 febbraio 2001, n. 31 "Attuazione della direttiva 98/83/CE relativa alla qualità delle acque destinate al consumo umano"

OTHER

German Federal Environmental Agency (UBA) "Acceptance of metallic material used for products in contact with drinking water Part B – 4MS with Common Composition Lists"

Decreto Ministero della Salute Decreto Ministero della salute 7 febbraio 2012, n. 25 Disposizioni tecniche concernenti apparecchiature finalizzate al trattamento dell'acqua destinata al consumo umano – Italian Degree

CERTIFICATION

D.M.25



Profine® Silver Mini

**Experimental information protocol
on the characteristics of devices
for the treatment of domestic drinking water**

By TIFQLAB

*Centre for the experimentation, research
and analysis of food technologies*

*Food Process Engineering Laboratory
of the University of Calabria*

Pursuant to Ministerial Decree n.25 of 7th February 2012,
Technical provisions concerning devices designed for the
treatment of water intended for human consumption.



Profine® Silver Small

Rende (CS), Wednesday 25 July 2012

**Experimental information protocol
on the characteristics of devices
for the treatment of domestic drinking water**

By TIFQLAB

*Centre for the experimentation, research
and analysis of food technologies*

*Food Process Engineering Laboratory
of the University of Calabria*

Pursuant to Ministerial Decree n.25 of 7th February 2012,
Technical provisions concerning devices designed for the
treatment of water intended for human consumption.



Profine[®] Silver Medium

Rende (CS), Friday 8 February 2013

**Experimental information protocol
on the characteristics of devices
for the treatment of domestic drinking water**

By TIFQLAB

*Centre for the experimentation, research
and analysis of food technologies*

*Food Process Engineering Laboratory
of the University of Calabria*

**Pursuant to Ministerial Decree n.25 of 7th February 2012,
Technical provisions concerning devices designed for the
treatment of water intended for human consumption.**



Profine® Silver Large

**Experimental information protocol
on the characteristics of devices
for the treatment of domestic drinking water**


By TIFQLAB

*Centre for the experimentation, research
and analysis of food technologies*

*Food Process Engineering Laboratory
of the University of Calabria*

**Pursuant to Ministerial Decree n.25 of 7th February 2012,
Technical provisions concerning devices designed for the
treatment of water intended for human consumption.**

CERTIFICATION
Kiwa



CERTIFICATE

Certificate number: 2101726

Date issued 13th January 2021

Date expired 12th January 2026 Original/Amendment *Original*

Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004
Reference Standards: Regulators Specification
Model Designations: see Appendix

Manufacturer: Think Water Srl.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification, which is managed in accordance with ISO/IEC 17065.

Signed on behalf of Kiwa Watertec

David Jay,
Business Unit Manager – Authorised Signatory
Kiwa Watertec

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate issued to:

Think Water Srl
Via delle Pezze, 35
35013 Cittadella
Padova
Italy



UK Approval Certificate (page 2 of 2)



Appendix to Certificate 2101726

The following products are covered by this certificate -

<p>PRODUCT DESCRIPTION: Range on inline filter cartridges with various filter medium depending on model variant. Having a plastic body and EPDM o rings. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S): Cartridge Profine Blue Small. Medium. Large (76 mm diameter, 300 - 420 - 560 mm height, 3.5 mm thickness); Cartridge Profine Silver Small. Medium. Large (same body and same dimensions of Blue, different colour); Cartridge Profine Violet Small, Medium, Large (same body and same dimensions, different colour); Cartridge Profine Lilac Small, Medium, Large (same body and same dimensions, different colour); Cartridge Profine Ocra Small. Medium. Large (same body and same dimensions, different colour); Cartridge Profine Big Violet 2.0 (137 mm diameter, 295 mm height, 5.0 mm thickness); Cartridge Profine Big Violet 3.0(137 mm diameter, 374 mm height, 5.0 mm thickness); Cartridge Profine Big Violet 4.0(167 mm diameter, 381 mm height, 7.5 mm thickness); Cartridge Profine Big Violet 6.0(173 mm diameter, 453 mm height, 7.5 mm thickness); Cartridge Profine Big Lilac 2.0. 3.0, 4.5, 6.0 (same body and dimensions, different colour); Cartridge Profine Big Ocra 2.0. 3.0. 4.5. 6.0 (same body and dimensions, different colour).</p> <p>NOTE: All cartridges are different and colour identifies the type of active material inside: - Blue family has standard active carbon. - Silver family has silver impregnated active carbon. - Violet family has weak cationic resin by Lenntech Lanxess plus silver carbon-block. - Lilac family has weak cationic resin by Purolite plus silver carbon-block. - Ocra family has strong cationic resin by Pure Resin and no silver carbon-block. - Blue and Silver shows 3 different sizes (same diameter, different height): Small, Medium and Large. - Violet, Lilac and Ocra can have Small, Medium and Large dimensions OR Big size (2, 3,4.5 and 6 litres capacity).</p>
<p>SIZE: 3/8" BSP (M).</p>
<p>SCOPE: Manufacturer recommended maximum working pressure 6 Bar & cold water use only. Hygienic purposes: Non-metallic materials suitable for continuous contact with cold water only. Above ground use only.</p>
<p>MATERIALS: Non-Metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES: N/A.</p>
<p>MARKING: Profine and other technical information on body.</p>
<p>ADDITIONAL NOTES: Opacity. Opacity cannot be guaranteed on this fitting. The fitting is to be so installed as to be readily accessible for examination, test, maintenance, replacement or operation. Water Undertakers cannot be responsible for the quality of water passed from these fittings.</p>

Extra Notes:

CERTIFICATION
WRAS



This certifies that

THINK WATER SRL

has had the undermentioned product(s) examined, tested and certified as being of an appropriate quality and standard as required in the Water Supply (Water Fittings) Regulations and Scottish Water Byelaws, subject to scheme requirements being met when installed.

Model Numbers

CARTRIDGE PROFINE RANGE OF FILTER CARTRIDGES

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Approvals Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

January 2026

Certificate No.

2101322

A handwritten signature in blue ink, appearing to read 'Ian Hughes', written in a cursive style.

Ian Hughes,
WRAS Approvals Manager



9th March 2021

Think Water Srl
Via Delle Pezze
35-35013 Cittadella
Padova
Italy

Water Regulations Advisory Scheme Ltd.
Unit 13, Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

Approval Number 2101322

Dear Sir/Madam

Production samples of the products described in the **Approval Information** section below ("Products"), have been subjected to the relevant mechanical and water quality tests as defined in Regulation 4 (2) and Schedule 2 to demonstrate a product is of an **appropriate quality or standard** for the purposes of a WRAS Approval application.

1. After considering the test reports and examining the Product/s, The Water Regulations Advisory Scheme Ltd. ("WRAS Ltd" / "WRAS") finds that:

The product is of an appropriate quality and standard as defined in The Water Supply (Water Fittings) Regulations 1999, The Water Supply (Water Fittings) (Scotland) Byelaws 2014, The Water Supply (Water Fittings) Regulations (Northern Ireland) 2009 and all other applicable WRAS requirements,

The non-metallic materials of construction, in contact with the water, are suitable for contact with wholesome water intended for domestic purposes having met the requirements of BS 6920-1: 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

2. WRAS Approvals are granted subject to, and in accordance with, the Standard Terms and Conditions of WRAS Approvals Schemes (WRAS.Cust-401) as amended from time to time ("Standard Terms of Approval").

You have confirmed your acceptance of the Standard Terms of Approval by submitting your application for WRAS Approval. A copy of the current Standard Terms of Approval are available from the WRAS website: www.wras.co.uk.

Terms defined in the Standard Terms of Approval shall have the same meaning in this letter unless the context otherwise requires.

3. Installation Requirements & Notes (IRNs) are set out in Appendix A. A Product only qualifies for Approval if WRAS is satisfied that the relevant Product complies with Regulation 4(1)(a) and the requirements of the Scheme when installed in accordance with the manufacturer's instructions and any applicable Approval Scheme Installation Requirements and Notes.

Since the incorrect installation of Products will not be within the scope of an approval and may result in contravention of the Regulations or Byelaws requirements, **the attention of your customers should be drawn to any IRNs applied.**

4. Please note that the use of the Products described in any particular area of supply is at the discretion of the Water Company (water undertaker) in that area.
5. Approval Holders may quote in their sales literature that their product is WRAS approved. A WRAS product approval demonstrates that a water fitting is of a suitable quality and standard, provided that it meets the requirements of the Scheme when installed in accordance with the manufacturer's instructions and any applicable Approval Scheme Installation Requirements and Notes
6. The "WRAS Approved Product" logos are certification marks registered under the Trade Marks Act 1994 ("Certification Marks"). Approval Holders may use the Certification Marks in accordance with the Standard Terms of Approval.
7. Please verify the details of your Product as set out in the approval information and advise us of any discrepancies by no later than .

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', written over a horizontal line.

Ian Hughes
WRAS Approvals Manager

APPROVAL INFORMATION

Validity dates:	This approval is valid for fittings (as listed below in model) manufactured AND installed between January 2021 & January 2026
Section Number:	1055
Section title:	FILTER CARTRIDGES
Installation requirement notes:	R001, R008,R120,R170,R290 (IRN's are set out in Appendix A)
Product description:	Range on inline filter cartridges incorporating plastic bodies. The filter media varies between models and includes active carbon, silver impregnated active carbon, silver carbon block & weak/strong cationic resin. Maximum working pressure 6.0 bar. Cold water use only.
Size:	See model
Identification Marking:	Profine and other technical information on body. Flow arrow on head unit.
Manufacturer:	Think Water Srl
Model:	33.65mm OD: Cartridge Profine Blue, Silver, Violet, Lilac and Ocra Small, Medium & Large. 3/8" BSP (M): Cartridge Profine Big Violet 2.0, 3.0, 4.0 & 6.0. Cartridge Profine Big Lilac 2.0, 3.0, 4.5, 6.0. Cartridge Profine Big Ocra 2.0, 3.0, 4.5 & 6.0.

Thinkwater srl
Via delle Pezze 35
35013 Cittadella (PD)
Italy

tel: + 39 049 9403526
fax: +39 049 8598579
mail: info@thinkwater.com

thinkwater.com
profine.com
shop.profinefilter.com

think:water
Profine®